CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 7165-1130:256 Page 1 of 2

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Honeywell International, Inc., 1500 W. Dundee Rd., Arlington Heights, IL 60004

Contact: Bob Hodgson (847) 797-4403 FAX (847) 797-3664

DESIGN: Model XLS3000 fire alarm control units. Local, auxiliary, remote station (PPU), proprietary

(PPU), central station (PPU), automatic, manual, waterflow and sprinkler supervisory services. Refer to listee's data sheet for detailed product description and operational considerations.

System components:

ACM-8R/-16AT/-24AT/-32A/-48A Annunciator Control Modules

ACPS-2406 Addressable/Charger Power Supply

AEM-16AT/-24AT/-32A/-48A Annunciator Expander Modules
AFM-16A/-16AT/-32A Annunciator Fixed Modules
XLS-AKS-1B Annunciator Key Switch

AMPS-24 Addressable Main Power Supply

APS-6R Auxiliary Power Supply ARM-4 Auxiliary Relay Module

BB-100/-200 Battery Box Blank Module

BGRA-SCS, BGRB-SCS, Smoke Control Enclosures for SCS Modules CEF-SCS, RSA-SCS, RSB-SCS, RSC-SCS, RSD-SCS, RSE-SCS Smoke Control Enclosures for SCS Modules Smoke Control Enclosures for SCS Modules

BP-4 Battery Panel XLS-BP2-4 Dress Panel

BX-501 Intelligent Detector/Sensor Base

B-501 Intelligent Base

B-710LP Intelligent Detector Base

CAB-4 Series Enclosure
CHG-120 Battery Charger
CHS-4L/-4MB/-4N/-6/-M3/-PS/*-BH1 Chassis
XLS3000-CPUND/-CPUD CPU Board

CRE-4 Control Relay Expander
CRM-4RK Control Relay Module
CRT-2 Display Terminal
DCM-4RK Dual Channel Module

DP-1B Blank Panel

DP-DISP Display Dress Panel DPDW-1B, DPSW-1B, XPDP Dress Panels

VP-2B Dress Panel DPI-232 Direct Panel Interface

FCPS-24 Field Charger/Power Supply ICE-4 Indicating Control Expander ICM-4RK Indicating Circuit Module IZE-A Initiating Zone Expander IZM-8RK Initiating Zone Module

ISO-X Isolator Module

LCD-80/-160 Liquid Crystal Display Module
LCM-320/LEM-320 Loop Expander Module
LDM-32/-E32/-R32 Lamp Driver Modules

MP-1B Blank Panel

MPS-24B Power Supply Module

XLS-MPS Addressable Manual Pull Station
XLS-NCA-2 Network Control Annunciator
NCM-W/-F Network Control Module
N-ELR End of Line Resistors

NFS-LBB/-LBBR/-BB-25/-BB-17 Battery Box XLS-PRN-6 Printer

R-120/-2.2K/-27K/-470/-47K End of Line Resistors
RA-400/-400Z Remote Annunciators
RKS-S Remote Security Keyswitch
RPJ-1 Remote Paging Jack

RPT-W/-F/-485W/-485WF Repeater

RM-1/-1SA Remote Microphone
SCS-8 Smoke Control Station
SCE-8 Smoke Control Expander
STS-1 Security Tamper Switch
TM-4 Transmitter Module

TR-A4/-B4/-C4/-D4 Trim Ring

UDACT Universal DACT
UZC-256 Universal Zone Coder
VCE-4 Voice Control Expander
VCM-4RK Voice Control Module
VS4095 Keltron Remote Printer

XP5-C/-M Transponder

XPC-8 Transponder Control Module

XPIQ Transponder Quad Intelligent Audio Module

XPM-8/-8L Transponder Monitor Modules
XPP-1 Transponder Processor
XPR-8 Transponder Relay Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating

devices. This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 2002 Edition. Refer to listee's Installation Instructions Manual for

details.

This control unit meets the requirements of UL-864, 8th Edition Standard.

NOTE: For *Fire Alarm Verification* feature (delay of fire alarm signal), the maximum

Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7165-0028:224

06-29-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 10, 2008 Listing Expires June 30, 2009

Authorized By: **BEN HO**, Chief

Fire Engineering Division